

	Request for Quotation		Doc. No	NLM-QUO-25/099
			Revision	1
			Page	1 of 4

RFQ Number	NLM-QUO-25/099
Request for Quotation Date	28 July 2025
RFQ Closing Date	29 August 2025
RFQ Closing Time	12:00
Compulsory Site Briefing	Not compulsory but if more information required can be arranged
Contact Person	Catherine Matima
Quotation Validity	90 Days from the closing date
Submission Details	RFQ Response must be sent to: Catherine.matima@necsa.co.za
RFQ Description	To supply pneumatic diaphragm pumps as per the attached specification sheets

Dear Service Provider

Kindly provide a quotation for goods and or services as outlined in section 3 of this document.

1. Introduction

The South African Nuclear Energy Corporation Limited (Necsa) is a state-owned public company (SOC), registered in terms of the Companies Act, (Act No. 61 of 1973), registration number 2000/003735/06.

The Necsa Group engages in commercial business mainly through its wholly-owned commercial subsidiaries: NTP Radioisotopes SOC Ltd (NTP), which is responsible for a range of radiation-based products and services for healthcare, life sciences and industry, and Pelchem SOC Ltd (Pelchem), which supplies fluorine and fluorine-based products. Both subsidiaries, together with their subsidiaries, supply local and global markets, earning valuable foreign exchange for South Africa and are among the best in their field in their respective world markets.

Necsa's safety, health, environment and quality policies provides for top management commitment to compliance with regulatory requirements of ISO 14001, OHSAS 18001 and RD 0034 (Quality and Safety Management Requirements for Nuclear Installations), ISO 9001 and ISO 17025.

Necsa promotes the science, technology and engineering expertise of South Africa and improves the public understanding of these through regular communications at various forums and outreach programmes to the community. We are a proudly South African company continuously striving, and succeeding in many respects, to be at the edge of science, technology and engineering related to the safe use of nuclear knowledge to improve our world.

For more information on Necsa, please visit: www.necsa.co.za

	Request for Quotation		Doc. No	NLM-QUO-25/099
			Revision	1
			Page	1 of 4

2. Background

Necsa plans to establish a plasma gasification demonstration facility in a laboratory on-site to volumetrically reduce uranium-containing PTFE candle filters. Pneumatic diaphragm (positive displacement) pumps are utilized on an ad hoc basis in various applications within the facility. A total of three pumps are required as follows:

- i) One pump, P83156, to periodically transfer a batch of aqueous solution containing 30% (w/w) potassium hydroxide from a make-up tank (T83155) to the sump tank of a wet scrubber (S83123). The solution is then used in the scrubber in a gas clean-up operation, until the solution becomes spent and must be disposed of.
Further detail of pump P83156 is provided in the attached Specification Sheet [01], and its position within the facility is shown in the attached Piping and Instrumentation Diagram (P&ID) [04].
- ii) One pump, P83165, to periodically transfer the batch of spent scrubbing solution from the sump tank of the scrubber (S83123) to a system of waste tanks (T83132A & B). The spent solution (effluent) then accumulates in the waste tanks until they are full and subsequently emptied.
Further detail of pump P83165 is provided in the attached Specification Sheet [02], and its position within the facility is shown in the attached P&ID [04].
- iii) One pump, P83166, to periodically service the waste tanks (T83132A & B) in two ways:
 - To homogenize the effluent in the tanks by recirculating it through a closed external loop.
 - To transfer the effluent from the tanks into a nearby road tanker for transport to an effluent processing facility.
 Further detail of pump P83166 is provided in the attached Specification Sheet [03], and its position within the facility is shown in the attached P&ID [04].

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

3. Scope of Work

Item Description	Quantity
To supply Pneumatic Diaphragm Pumps, as per the attached Specification Sheets, [01], [02] and [03]. NOTES: 1. The air supply pressure regulator, complete with pressure gauge, must be supplied with each pump. 2. The moving parts of the pneumatic section of the pumps must not need lubrication. 3. All other equipment and components identified and referenced in Section 2 and/or P&ID [04] are outside the scope of work considered here.	3

4. Attachments

Ref #	DOCUMENT NAME	DESCRIPTION
01	ENS-FDP-SPE-24010, Rev 2	Specification Sheet for Diaphragm Pump P83156
02	ENS-FDP-SPE-24011, Rev 2	Specification Sheet for Diaphragm Pump P83165
03	ENS-FDP-SPE-24012, Rev 2	Specification Sheet for Diaphragm Pump P83166
04	ENS-FDP-PID-24003, Rev. 6	PTFE Facility Destruction Project: P&ID Diagram – KOH Scrubber System 831

5. Pricing

- All price quoted to include all applicable taxes.
- Price must be fixed and firm.
- Price should include additional cost elements such as freight, insurance until acceptance, duty where applicable, disbursements etc.
- Quotation must be completed in full, incomplete quote could result in a quote being disqualified.
- Payment will be according to Necsa's General Conditions of Purchase.

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

6. Evaluation

6.1. Phase 1- Functionality Evaluation / Technical Evaluation

Where functional or technical evaluation criterion is applicable, assessment will be performed in terms of the criterion listed below and the criterion may include Technical, Performance, Quality and Risk.

If the Bidder's response to the Technical templates does not indicate that the Bidder can support an acceptable technical solution, the Bidder's response will be rejected and not evaluated further.

Together the Technical, Performance & Quality and Risk criteria make up the functionality criterion and a Bidder's Proposal will be evaluated for functionality out of a possible 100 points. Only RFQ responses achieving an evaluation score of greater than the set threshold points out of the possible 100 points and which score a number of points for functionality that is greater than or equal to the set threshold points of the number of points achieved by the highest scoring Bid for functionality will be selected to progress to the second stage.

The quotations will be evaluated according to the following selection criteria (based on information requested above):

Item	Requirement	Weight	Points	Criteria
1	ISO 9001: 2015 (or latest) accredited Supplier must provide evidence (ISO 9001 certificate)	25	25	a) ISO 9001 accreditation of supplier, if the supplier is the OEM of the required product. OR b) ISO 9001 accreditation of OEM, if the supplier is not the OEM of the required product.
2	Supplier must provide letter referencing after sales service and maintenance NOTE: If supplier has a service and repair workshop, but is not the OEM, then an OEM letter is required, listing the local supplier as an authorised service agent for the product in South Africa.	25	25	Supplier having a service and repair workshop and holds critical spares as stock items
			15	Supplier having a service and repair workshop but does not hold critical spares as stock items
			10	Supplier outsources service and repair

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

Item	Requirement	Weight	Points	Criteria
3	Supplier lead-time Supplier must specify lead-time	25	25	Product available within 4 weeks of issue of Purchase Order
			15	Product available within 6 weeks of issue of Purchase Order
			10	Product available within 8 weeks of issue of Purchase Order
4	Suitability of Product Supplier must provide details of the make and model, as well as datasheets and performance curves for each of the recommended pumps.	25	25	Supplier adequately demonstrates how the recommended product meets the user's requirements defined in the Specification Sheets [01], [02] and [03]
Total		100		

Note: Bidders that score <80 out of 100 in respect of Technical/Functional evaluation criteria will be regarded as submitting a non-responsive bid and will not be evaluated further.

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

6.2. **Phase 2 - Evaluation In Terms Of Preferential Procurement Policy Framework Act, 2022**

This bid will be evaluated and adjudicated according to the 80/20 point system, in terms of which a maximum of 80 points will be awarded for price and 20 points will be allocated based on the specific goals (B-BBE status level).

	POINTS
PRICE	80
SPECIFIC GOALS (B-BBEE status level)	20
Total points for Price and SPECIFIC GOALS	100

Preference goal
B-BBEE status level contributor

B-BBEE Status Level of Contributor	Number of points (80/20 system)
1	20
2	18
3	14
4	12
5	8
6	6
7	4
8	2
Non-compliant contributor	0

7. **Required Documentation**

- Tax Clearance Certificate (Tax pin issued by SARS)
- Declaration of interest (SBD 4)
- BEE Certificate / Applicable Affidavit if classified as EME
- Letter of Good Standing (COID) only if Applicable due to the nature of work required
- Any other document or certification that might have been requested on this RFQ

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

8. Important

- 8.1. Quotation must be submitted on or before the RFQ closing date and time stated above.
- 8.2. Orders above R 30 000 will be evaluated according to the PPPFA 80/20-point system and a functionality scorecard where applicable and the ones above R 1 Million will be subjected to the tender process.
- 8.3. This RFQ is subjected to the Necsa's General Conditions of Purchase, Preferential Procurement Policy Framework Act 2000 and the Preferential Procurement Regulations, 2022, the General Conditions of Contract (GCC) and, if applicable, any other legislation or special conditions of contract.
- 8.4. Failure on the part of a bidder to submit proof of B-BBEE Status level of contributor together with the bid, will be interpreted to mean that preference points for specific goals are not claimed.
- 8.5. The purchaser reserves the right to require of a bidder, either before a bid is adjudicated or at any time subsequently, to substantiate any claim in regard to specific goals, in any manner required by the purchaser.
- 8.6. For a Bidder to obtain clarity on any matter arising from or referred to in this document, please refer queries, in writing, to the contact details provided above. Under no circumstances may any other employee within Necsa be approached for any information. Any such action might result in a disqualification of a response submitted in competition to this RFQ.
- 8.7. No goods and/or services should be delivered to Necsa without an official Necsa Purchase order.
- 8.8. Necsa reserves the right to; cancel or reject any quote and not to award the RFQ to the lowest Bidder or award parts of the RFQ to different Bidders, or not to award the RFQ at all.
- 8.9. The supplier shall under no circumstances offer, promise or make any gift, payment, loan, reward, inducement, benefit or other advantage, which may be construed as being made to solicit any favour, to any Necsa employee or its representatives. Such an act shall constitute a material breach of the Agreement and the Necsa shall be entitled to terminate the Agreement forthwith, without prejudice to any of its rights
- 8.10. By responding to this request, it shall be construed that: the bidder, hereby acknowledge to be fully conversant with the details and conditions set out in the

	Request for Quotation	Doc. No	NLM-QUO-25/099
		Revision	1
		Page	1 of 4

Necsa's General Conditions of Purchase, Preferential Procurement Policy Framework Act 2000 and the Preferential Procurement Regulations, 2022, the General Conditions of Contract (GCC), Technical Information and Specifications attached, and hereby agree to supply, render services or perform works in accordance therewith.