

Attention: Tenderers

Date: 01.10.2026

Enquiries: Tlhogelo Mahlape
Tel +27 15 230 1773

Dear Sir/Madam

ADDENDA 01 TO INVITATION TO TENDER FOR ENQUIRY NO E3463DXLIMOU FOR:

The supply of various electrical cables, conductors and concentric cables to Eskom warehouses within Limlanga Cluster on an “as and when” required basis over a period of 24 months.

1. Please take note of the following questions that were made on Enquiry No: E3463DXLIMOU

Question	Answer
1. May you please advise whether you would accept wooden drums for the overhead conductors.	We do not accept wooden drums. Only hybrid drums will be considered.
2. Clarify that the specification reference for the Saferdac type test should be SANS 1507-6, and not SANS 1418. 3. Section 3.4 of the technical criteria – the table references SANS 14/18 instead of the correct SANS standard numbers for concentric cable and LVABC cable. Please clarify.	Kindly note the correction: the reference was a typing error. Concentric cable shall be in accordance with SANS 1507, and LV ABC cable shall be in accordance with SANS 1418. The revised 240-125775345 Technical Evaluation Criteria (6sq mm) Rev 3 Report is uploaded.
4. As an authorised distributor of the OEM's electrical cables, can we authorise another company to resell and bid with the OEM's products, or must the bidder obtain authorisation directly from the OEM to be compliant	It is the supplier's responsibility to identify and engage the relevant OEM and obtain the required OEM authorisation. Accordingly, Eskom cannot advise distributors on which OEM to approach or how to obtain such authorisation.
5. NEC Contract, page 9, item 88.5: The End of Liability is specified as 15 years after delivery of goods. The industry-accepted standard warranty period for factory defects on cable products is 1 year. Please clarify this requirement.	The end of liability date will be revised to 12 months

Procurement and Supply Chain Management

90 Hans Van Rensburg Street

POLOKWANE

Private Bag X9477 POLOKWANE 0700 SA

Tel +27 15 230 1773 www.eskom.co.za

Eskom Holdings SOC Ltd Reg No 2002/01527/30

6. May you please confirm the below: The tender price will be fixed for the first year and then CPA adjusted but that will be negotiated with the awarded supplier (CPA will be negotiated with the suppliers to ensure alignment to Eskom CPA guideline).	See the outlined CPA application, Annexure E, page 44 to 45 of the Invitation to Tender. CPA will not be applicable for the first year and be applied from year 2.									
7. May you please advise if the delivery will be done by the supplier or Rotek on this tender. 8. Can you please confirm if we should quote including delivery or will Rotran Collect?	Eskom Rotek Industries will be delivering the material									
9. Kindly see the attached overview for the LV and MV cables. Regarding the technical evaluation, it refers to a letter. Could you please advise whether the attached overview, provided on our company letterhead, will be acceptable as sufficient or if we need to draft a formal letter with an authorised signatory? Table 2: MV XLPE Cable Mandatory Technical Evaluation Criteria <table><tr><th colspan="3">TASK / MEASURE</th></tr><tr><th>Criteria</th><th>Standard/Documentation Applicable</th><th>Acceptance: Yes/ No</th></tr><tr><td>1) Is a covering letter listing all items tendered for with the OEM and product code indicated submitted?</td><td>Letter</td><td></td></tr></table>	TASK / MEASURE			Criteria	Standard/Documentation Applicable	Acceptance: Yes/ No	1) Is a covering letter listing all items tendered for with the OEM and product code indicated submitted?	Letter		I cannot confirm whether the letter is correct or incorrect. Please refer to requirements and criteria stipulated in the tender document and ensure that your submission fully complies with them.
TASK / MEASURE										
Criteria	Standard/Documentation Applicable	Acceptance: Yes/ No								
1) Is a covering letter listing all items tendered for with the OEM and product code indicated submitted?	Letter									

2. The scope of work was amended to correct the contract period from one year to two years on page 1 under item 2 – scope.
3. The revised 240-125775345 Technical Evaluation Criteria (6sq mm) Rev 3 Report is uploaded.
4. The NEC Contract was amended as follows

Original The end of liability date is	Revised The end of liability date is
15 years after Delivery of the whole of the goods and services.	12 months (1 year) after Delivery of the whole of the goods and services.

5. The invitation to tender has been amended as follows: new tender closing date is 14 October 2026 at 10:00 am.

Original Closing Date and Time	Revised Closing Date and Time
05 October 2026; 10:00am	14 October 2026; 10:00am

The amended invitation to tender, scope of work and NEC Contract have been uploaded in the Eskom Tender Bulletin and the National Treasury e-tender portal.

Kindly note that **No late tender submission** will be accepted.

Yours sincerely



Madimetja Phalane
Procurement Manager- Limlanga Cluster